

1
2
3
4 **A Sustainable Framework for Multi-Microgrids Energy Management in**
5 **Automated Distribution Network by Considering Smart Homes and High**
6 **Penetration of Renewable Energy Resources**
7

8 S. A. Mansouri ^{1*}, A. Ahmarinejad ², E. Nematbakhsh ³, M. S. Javadi ⁴
9 A. Esmael Nezhad ⁵ and J. P. S. Catalão^{4,6}
10

11
12 ¹Department of Electrical Engineering, Yadegar-e-Imam Khomeini (RAH) Shahre Rey Branch, Islamic Azad
13 University, Tehran, Iran

14 ²Department of Electrical Engineering, Central Tehran Branch, Islamic Azad University, Tehran, Iran

15 ³Faculty of Electrical Engineering, University of Isfahan, Isfahan, Iran

16 ⁴Institute for Systems and Computer Engineering, Technology and Science (INESC TEC), Porto, Portugal

17 ⁵Department of Electrical, Electronic, and Information Engineering, University of Bologna, Bologna, Italy

18 ⁶Faculty of Engineering of the University of Porto, Porto, Portugal
19
20
21
22

23 **Abstract**
24

25 This paper presents a new framework for the scheduling of microgrids and distribution feeder
26 reconfiguration (DFR), taking into consideration the uncertainties due to the load demand, market
27 price, and renewable power generation. The model is implemented on the modified IEEE 118-bus
28 test system, including microgrids and smart homes. The problem has been formulated as a two-
29 stage model, which at the first stage, the day-ahead self-scheduling of each microgrid is carried
30 out as a two-objective optimization problem. The two objectives include the minimization of the
31 total operating cost and maximization of the consumer's comfort index. Then, the solution,
32 obtained from the first stage is delivered to the distribution system operator (DSO). Then, at the
33 second stage, the DSO determines the optimal configuration of the system with the aim of
34 minimizing operating costs of the main grid and the penalty of deviating from microgrid
35 scheduling. Note that the penalty is due to the difference in power exchange requested by the
36 microgrids from the power exchange finalized by the DSO. The presented two-stage optimization
37 problem is modeled in a mixed-integer linear programming (MILP) framework with four case
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59

60 * Amir.mansouri24@gmail.com
61
62
63
64
65

1
2
3
4 studies, and solved in GAMS by using the GURUBI solver. The simulation results show that in
5
6 the cases the DSO is able to reconfigure the system, the deviation from the optimal scheduling of
7
8 microgrids would be considerably lower than the cases with fixed system configuration.
9

10
11 **Keywords:** Multi-objective optimization; Distribution feeder reconfiguration; Microgrids;
12
13 Renewable energy resources, Smart homes; Consumers' comfort index.
14

15 16 **Nomenclature**

17 **Abbreviations**

18 CV	Convenience Value
19 ENS	Energy Not Supplied
20 EEC	Estimated Energy Consumption
21 LOT	Length of Operation Time
22 PCV	Preferred Convenience Value
23 PTR	Preferred Time Range
24 UCL	User's Convenience Level
25 UTR	Utilization Time Range

26 **Indices**

27 D_i^g	Set of connected gas turbines to network buses
28 D_{mg}^i	Set of connected network buses belongs to microgrids
29 D_i^{st}	Set of connected network buses to substation
30 D_i^{pv}	Set of connected Photovoltaic panels to network buses
31 D_i^w	Set of connected wind turbines to network buses
32 $D_{mg,t}^{j-}$	Dynamic set of connected network branches to microgrid with negative flow
33 $D_{mg,t}^{j+}$	Dynamic set of connected network branches to microgrid with positive flow
34 g	Gas turbine index
35 h	Heaviside time window index
36 i,j	Network bus index
37 mg	Microgrid service area index
38 l	Branch index
39 n,m	Appliances index
40 pv	Photovoltaic panel index
41 PTR^n	Preferred time range of appliances
42 s	Scenario index
43 st	Substation index
44 t,tt	Time index
45 UTR^n	Utilization time range of appliances
46 w	Wind turbines index

47 **Scalars**

48 Δt	Time step (h)
---------------	---------------

1		
2		
3		
4	η^{ch} / η^{dch}	Charging/Discharging efficiency of EES (%)
5		
6	η^{conv}	EES's converter efficiency (%)
7	η_{pv}^{conv}	PV's converter efficiency (%)
8		
9	η^{gen}	Gas turbines efficiency (%)
10	M	A positive big number
11	N^{sw}	Total switching limit
12		
13	Parameters	
14	β_n	Damping coefficient in preferred convenience curve
15	EEC_n	Estimated energy consumption of appliances (kWh)
16	E_w^0 / E_{pv}^0	Initial stored energy in EES units (kWh)
17		
18	E_w^{max} / E_{pv}^{max}	Maximum rate of energy stored in EES units (kWh)
19		
20	E_w^{min} / E_{pv}^{min}	Minimum rate of energy stored in EES units (kWh)
21	$G_{i,j}^{line} / B_{i,j}^{line}$	Conductance/Susceptance of network branches (S)
22		
23	G_{std}	Irradiation of sun at the standard condition (W/m ²)
24	LOT_n	Length of operation time of appliances (h)
25	$P_{i,t,s}^{fix}$	Active fix demand in network buses (kW)
26		
27	π_t^e	Electricity price (\$/kWh)
28		
29	π_g^{gen}	Gas price (\$/kWh)
30	$\pi_{mg}^{penalty}$	Penalty cost for deviating from the microgrids scheduling (\$/kWh)
31		
32	P_g^{min} / P_g^{max}	Max/Min active power generation limit of gas turbines (kW)
33	$P_w^{ch,max} / P_{pv}^{ch,max}$	Maximum charging rate of EES units (kW)
34	$P_w^{dch,max} / P_{pv}^{dch,max}$	Maximum discharging rate of EES units (kW)
35		
36	P_{pv}^r	Rated active power of Photovoltaic panels (kW)
37	P_w^r	Rated active power of wind turbines (kW)
38		
39	π_{pv}^{solar}	Solar power price (\$/kWh)
40	π_w^{wind}	Wind power price (\$/kWh)
41		
42	Q_g^{min} / Q_g^{max}	Max/Min reactive power generation limit of gas turbines (kVar)
43	$r_{i,j} / x_{i,j}$	Resistance/Reactance of network branches (ohm)
44		
45	ρ_s	Probability of scenario s (%)
46	S_b / S_b^2	Base/Quadratic value of Piecewise block (kVA/kVA ²)
47	$S_{i,j}^{max}$	Maximum Apparent power of network branches (kVA)
48		
49	$\theta_{i,t,s}^{min} / \theta_{i,t,s}^{max}$	Max/Min voltage Angle (rad)
50		
51	T_{n_1, n_2}^{gap}	Maximum time gap between consecutive appliances (h)
52	t_n^{start} / t_n^{end}	Starting/ending points of PTR for appliances (h)
53		
54	$V_{i,t,s}^{min} / V_{i,t,s}^{max}$	Max/Min voltage Magnitude (p.u.)
55	$v_t / v_r / v_o$	Wind turbine characteristics (cut-in/rated/cut-out speed) (m/s)
56		
57	w_n	Weight coefficient of appliances
58	$\zeta_{i,j}^{line}$	Power factor of network branches
59		
60	Variables	
61		
62		
63		
64		
65		

1		
2		
3		
4		
5	$\alpha_{i,j,t,s,b}$	The piecewise block operating point
6	$C_{g,t,s}^{gen}$	Operating cost of micro turbines (\$)
7	$C_{pv,t,s}^{solar}$	Operating cost of PV panels (\$)
8		
9	$C_{w,t,s}^{wind}$	Operating cost of wind turbines (\$)
10	$Cost_{mg,s}$	Operation cost of microgrid (\$)
11	$CV_{i,s,n}$	User's convenience value (%)
12		
13	$Comfort_{mg,s}$	Users' comfort level in each microgrid (%)
14		
15	$E_{w,t,s} / E_{pv,t,s}$	Energy stored in EES (kWh)
16	$G_{pv,t,s}$	Sun irradiance (W/m ²)
17	μ	Multi-Objective normalized value
18	μ^1	Normalized value of Operation cost
19		
20	μ^2	Normalized value of Users' comfort level
21		
22	$P_{pv,t,s}^{solar}$	Active generated power by PV panel (kW)
23	$P_{w,t,s}^{wind}$	Active generated power by wind turbines (kW)
24		
25	$P_{i,j,t,s}^{loss}$	Active power loss in network branches (kW)
26	$P_{i,t,s,n}^{schedule}$	Active schedulable demand in network buses (kW)
27		
28	$P_{g,t,s}^{gen} / Q_{g,t,s}^{gen}$	Active/Reactive generated power by gas turbines (kW/kVar)
29	$P_{i,t,s}^{demand} / Q_{i,t,s}^{demand}$	Active/Reactive power demand in network buses (kW/kVar)
30		
31	$P_{st,t,s}^{sub} / Q_{st,t,s}^{sub}$	Active/Reactive power generation of substations (kW/kVar)
32	$P_{i,t,s}^{inj} / Q_{i,t,s}^{inj}$	Active/Reactive power injection at network buses (kW/kVar)
33		
34	$P_{i,j,t,s}^{line} / Q_{i,j,t,s}^{line}$	Active/Reactive power transferred in network branches (kW/kVar)
35	$P_{i,j,t,s}^{line,req}$	Requested power exchange by the microgrids (kW)
36		
37	$P_{w,t,s}^{ch}$	Charging active power of EES units (kW)
38	$P_{pv,t,s}^{dch}$	Discharging active power of EES units (kW)
39		
40	$PCV_{t,n}$	Preferred convenience value (%)
41		
42	$S_{i,j,t,s}^{line}$	Apparent power transferred in network branches (kVA)
43	$\theta_{i,t,s}^{bus}$	Angle of voltage in network buses (rad)
44	$UCL_{\gamma,s}$	User's convenience level (%)
45		
46	$V_{i,t,s}^{bus}$	Magnitude of voltage in network buses (p.u.)
47	$v_{w,t,s}$	Wind speed (m/s)

Decision Variables

48		
49		
50	$I_{i,t,s,n}^{appliance}$	Indicator for scheduling appliances
51	$I_{pv,t,s}^{ch} / I_{pv,t,s}^{dch}$	Indicator of PV panels' EES in charging/discharging mode
52		
53	$I_{w,t,s}^{ch} / I_{w,t,s}^{dch}$	Indicator of wind turbine's EES in charging/discharging mode
54	$I_{l,t}^{flow}$	Indicator for status of network branches
55		
56	$I_{i,j,t}^{flow} / I_{j,i,t}^{flow}$	Indicator of power flow direction in network branches
57		
58	$I_{g,t,s}^{gen}$	Indicator of gas turbines
59	$I_{i,t,s,n,h}^{step}$	Indicator of time window
60		
61		
62		
63		
64		
65		

$$I_{i,t,s,n}^{turn-on} / I_{i,t,s,n}^{turn-off}$$

Indicator of starting/ending points for scheduling appliances

1-Introduction

1-1- Background and Motivation

In the last two decades, with the restructuring of the electricity market, the penetration rate of local generation units in distribution systems has increased dramatically. Generation units consist of renewable or non-renewable energy sources and provide the load of the customers near the consumption points. In modern distribution systems, these generation units are integrated with electrical energy storage (EES) systems and managed by a central control system, which is called the microgrid [1]. It should be mentioned that the microgrid can operate in both grid-connected and islanded modes. In the grid-connected mode, microgrid is able to exchange power with the distribution system, while in islanded mode, the microgrid uses its own generation units and EES systems to meet the demand of its consumers [2].

Microgrids play an important role in transforming existing grids into smart grids. Generally, microgrids lead to reduced operating costs, reduced emissions, improved energy efficiency, and increased system reliability. It should be noted that in the problem of integrated operation of microgrids, in addition to the economic aspects, the technical and security aspects must also be considered [3]. Therefore, in this paper, a two-stage framework is presented, in the first level of which each microgrid does its day-ahead scheduling taking into account the technical and economic aspects, and then in the second stage, the final scheduling of the entire network with consideration of security aspects is done by DSO.

Recently, the focus of many studies has been on achieving a more sustainable structure for the integrated energy management of multiple microgrids. In the competitive market, the main purpose of microgrids is to meet the demand of their consumers at the lowest cost. It should be

1
2
3
4 noted that the operating cost of microgrids depends on their day-ahead scheduling [4].
5
6 Uncertainties due to load, renewable energy resources (RERs) power generation and electricity
7
8 prices significantly affect microgrid scheduling and pose a serious challenge for microgrid
9
10 operators [5]. Therefore, it is important to consider these uncertainties in microgrid scheduling
11
12 problem. In this regard, in this paper, uncertainties of load demand, electricity prices and output
13
14 power of RERs are considered so that scheduling is robust against the fluctuations of generation
15
16 and consumption.
17
18
19
20

21 The use of EES systems is one of the most effective approaches to deal with uncertainties and
22
23 increase system flexibility [6]. EES systems, if installed next to RERs, store the surplus generation
24
25 of these resources and then inject it into the network during peak hours. This performance not only
26
27 prevents the curtailment of excess RERs power but also reduces operating cost. Besides, the
28
29 shortage of generation of RERs due to unfavorable weather conditions can be compensated by the
30
31 energy stored in EES systems. It should be noted that in the model proposed in this paper, an EES
32
33 system is considered next to each RER.
34
35
36
37

38 The other two approaches to enhance operational flexibility are DFR and the demand response
39
40 programs. By implementing DFR, the system operator changes the network topology in order to
41
42 achieve goals such as reducing operating costs, reducing losses, and enhancing reliability. It should
43
44 be mentioned that DFR is only applicable to radial networks. Noted that in the model proposed in
45
46 this paper, DFR is performed by DSO with the aim of reducing the deviation of the final schedule
47
48 of microgrids from their optimal schedule [7]. The participation of traditional and smart loads in
49
50 demand response (DR) programs and the use of their active role in the electricity market can be an
51
52 important help to improve system flexibility. On the other hand, participation in DR programs
53
54 improves the load demand curve of consumers and reduces operating costs. Noted that the
55
56
57
58
59
60
61
62
63
64
65

1
2
3
4 implementation of DR programs should be such that the comfort index of consumers always
5
6 remains at a desirable level. Hence, in this paper, the consumers' comfort index is considered as
7
8 one of the objectives of the problem.
9

10 11 **1-2 Literature Review**

12
13
14 Increasing the penetration rate of RERs in distribution systems, despite reducing emissions and
15
16 operating costs, has led to increased operating uncertainties [8]. Therefore, many studies have
17
18 examined the problem of microgrid energy management by considering uncertainties. For
19
20 instance, Ref. [9] provides a new framework for energy management of residential microgrids, in
21
22 which the ten-state Markov chain is used to model the uncertainty of photovoltaic (PV) panels'
23
24 generation. The proposed model is implemented on a real case study in France and the results show
25
26 an improvement in performance and a 13.2% increase in microgrid profits. Ref. [10] provides a
27
28 framework for microgrid energy management. In this study, rolling time horizon, adaptive neuro-
29
30 fuzzy inference systems trained by clustering and neuro-fuzzy min-max classifier, Mamdani fuzzy
31
32 inference system, support vector regression, echo state network and multilayer perception
33
34 strategies are utilized for energy management system modeling and the results indicate that the
35
36 rolling time horizon method has a more accurate performance in predicting in the presence of
37
38 uncertainties. Also, in this study, a graphical interface is proposed to display the energy flow in
39
40 each microgrid. In [11] a fuzzy logic-based energy management framework is presented for
41
42 microgrids. The objective function of the proposed model is profit maximization of microgrid and
43
44 in order to solve it, a hierarchical genetic algorithm has been utilized. The results of this study
45
46 mirrored that the proposed model has improved system performance related to the profit by about
47
48 10%. Ref. [12] presents a two-stage stochastic framework for microgrid energy management, in
49
50 which Apache Spark is used to improve the performance of the scalable stochastic optimization
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65

1
2
3
4 model. In this study, to deal with wind speed uncertainties, the problem is formulated based on
5 chance constrained method. The model is solved using both historical information and Apache
6 Spark methods, and the results show that the use of Apache Spark has reduced production costs
7 by 3.92% and improved system resilience.
8

9
10
11
12
13
14 As mentioned, DFR enhances system flexibility by rerouting power flow [13]. Therefore, in many
15 studies, microgrid scheduling has been done considering DFR implementation. Ref. [7] provides
16 a coordinated model for microgrid scheduling, in which DFR, DR programs, and EES systems are
17 considered to enhance operating flexibility. In this study, an improved point estimation method
18 (PEM) has been used to model the output power uncertainties of wind turbines and PV panels and
19 the objective function is to minimize the operating cost of microgrid. The model is implemented
20 on a 33-bus distribution network and the results demonstrate that the proposed model has reduced
21 losses by 34.03%. Also, the results show that the implementation of DFR has led to a 10.83%
22 reduction in the cost of purchasing energy. Ref. [14] has used the coordinated implementation of
23 DFR and DR program in order to optimally exploit the distribution system. In this study, the
24 conditional value-at-risk (CVaR) model is used to model the consumers' comfort index, which
25 considers the risk of exceeding the comfort limit. In order to model wind speed uncertainties,
26 Markov decision process (MDP) is utilized and the results indicate that the coordinated
27 implementation of DFR and DR program covers wind speed prediction error. The results also
28 illustrate that the MDP method has reduced operating costs by 2% to 7% compared to the stochastic
29 method. Ref. [15] presents a deterministic multi-objective model based on the chaos disturbed
30 beetle antennae search (CDBAS) optimization algorithm. The objectives of this research are loss
31 minimization, load balance index and voltage deviation index and the proposed model has been
32 implemented on both 69-bus and 118-bus distribution networks. Finally, the results show that the
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65

1
2
3
4 use of the CDBAS algorithm not only increases the solution speed but also reduced losses in 69-
5 bus and 118-bus networks by 39.42% and 10.99%, respectively. Ref. [16] introduces an energy
6 management framework to cover phase balancing in grid interfaced photovoltaic / fuel cell system.
7
8 In this regard, a phase balancing control method is provided to maintain network quality in
9 unbalanced loading situations. The effectiveness of the proposed model has been proven by
10 implementing on different networks.
11
12
13
14
15
16
17

18
19 With the advent of DR programs in the last two decades, the role of end-users in the power market
20 has become much more prominent [17]. Meanwhile, smart homes have a greater impact on system
21 operation than traditional homes, due to their Internet of Things (IoT)-based appliances. One of
22 the constraints that must be considered during the implementation of DR programs is the
23 consumers' comfort index. Hence, in recent years, many researches have done microgrid
24 scheduling considering consumers' comfort index. In Ref. [18], the problem of smart home energy
25 management is solved by considering a price-based DR (PBDR) program. The objectives of this
26 model include reducing operating costs, improving consumers' comfort index and alleviating peak
27 to average ratio (PAR), and the wind-driven bacterial foraging algorithm (WBFA) has been
28 utilized to solve the model. The proposed algorithm automatically responds to PBDR programs to
29 deal with the major problem of these programs, which is the limitation of consumer's knowledge
30 in response to receiving DR signals. The simulation results show that applying DA, RTP and TOU
31 pricing programs reduced costs by 27.6%, 40% and 52.1%, respectively. Ref. [19] presents a
32 model for energy management of a smart home in the presence of RER, EES systems and electric
33 vehicles. In the proposed model, the investment costs of EES systems and electric vehicles are
34 considered and the final model is formulated as a MILP problem. The simulation results
35 demonstrate that smart home appliance scheduling with the participation of EES and electric
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65

1
2
3
4 vehicles not only reduces the operating cost by about 29% but also improves the comfort index of
5
6 consumers. In [20], a deterministic multi-objective optimization framework for energy
7
8 management of a residential microgrid is presented, in which smart home appliances scheduling
9
10 is done based on IoT concept. In order to solve the model, the improved butterfly optimization
11
12 algorithm is utilized and the results indicate that this algorithm leads to an increase in convergence
13
14 speed. Also, the results show that the operation of the microgrid in the island mode increases the
15
16 operating cost by 9% to 17%. In [21], smart home scheduling has been done using a scheduling
17
18 algorithm consisting of three artificial intelligence techniques. In the proposed model, support
19
20 vector regression is used to predict the power of the next day and the level of consumers' comfort
21
22 index is determined by the K-means clustering algorithm. The scheduling problem is modeled as
23
24 a two-objective optimization problem, the objectives of which include operating costs and
25
26 consumers' comfort index. Finally, the scheduling problem is solved by the NSGA-II algorithm
27
28 and the results show that the proposed model reduces the operating cost by 51.4%.
29
30
31
32
33
34
35

36 The authors in [22] present a model for the optimal operation of electricity and gas networks in
37
38 the presence of smart homes, electric vehicles (EVs) and a new hybrid heating system. The
39
40 proposed model is formulated in a two-objective form, the objectives of which are to minimize the
41
42 cost of scheduling and minimize the discomfort index. Smart homes are considered as flexible
43
44 loads and the simulation results show that the use of hybrid heating system reduces 22.8% and
45
46 21% of operating costs in electricity and gas networks, respectively. Ref. [23] presents an optimal
47
48 model for energy management of a smart building equipped with PV-thermal panels. In the
49
50 proposed model, a heating storage system is used for better exchange with electricity and heat
51
52 networks. The case study is a real building in Western Denmark and the results show that PV-
53
54 thermal panels have led to more efficient use of solar radiation energy. The authors in [24]
55
56
57
58
59
60
61
62
63
64
65

1
2
3
4 proposed a robust optimization model for the operation of interconnected microgrids in which
5
6 several energy hubs are considered. In order to ensure the privacy of microgrids and the
7
8 decentralization of the scheduling problem, the alternating direction method of multipliers
9
10 (ADMM) has been utilized. The results show that doubling the system robustness rate leads to a
11
12 19% increase in operating cost. Ref. [25] presents a multi-objective model for energy management
13
14 of multi-microgrids in the presence of EVs. In this study, an enhanced neural network method has
15
16 been utilized to predict the charging pattern of EVs. Objective-functions include losses, operating
17
18 costs and emissions, and the results indicate that using the enhanced neural network method
19
20 proposed in this study reduces the forecast error by 36.86%. The authors in [26] proposed a two-
21
22 objective model for the coordinated operation of electricity and gas networks in the presence of
23
24 smart homes. The epsilon-constrained method is employed for two-objective modeling of the
25
26 optimization problem and the objective functions are operation cost and emissions. The problem
27
28 is modeled as MILP problem and the results indicate that a 2.87% reduction in emissions leads to
29
30 a 0.75% increase in operating cost. In addition, the results show that a 21.93% increase in the
31
32 comfort index increases the operating cost by 41%. An energy management framework for day-
33
34 ahead scheduling of interconnected microgrids considering DR program is presented in [27]. In
35
36 this study, microgrids use a novel deep-learning artificial neural network (ANN) model to predict
37
38 load demand and generation of RERs, and the results demonstrate that the coordinated
39
40 performance of EES systems and DR program has led to a reduction in operating costs.
41
42
43
44
45
46
47
48
49

50 **1-3- Research Gap**

51
52 Table 1 provides a comparison between the model proposed in this paper and recent studies. A
53
54 review of recent researches shows that most studies have solved the DFR problem with the aim of
55
56 reducing losses, voltage stability and enhancing reliability, and none of the studies has solved the
57
58
59
60
61
62
63
64
65

1
2
3
4 DFR problem in the presence of smart homes and considering the comfort index of customers.
5
6
7 Therefore, in this paper, a comprehensive model is presented in which microgrids include
8
9 traditional and smart homes and the DFR problem is solved according to the operation cost and
10
11 the comfort index of the customers.
12

13 14 **1-4- Contribution**

15
16 This paper presents a two-stage framework for the scheduling of microgrids and DFR. The model
17
18 has been implemented on the modified IEEE 118-bus test system, including ten microgrids with
19
20 traditional loads and smart homes. Besides, the uncertainties due to the load demand, market price,
21
22 and renewable power generation have been applied to the model to take into consideration realistic
23
24 conditions. The problem has been formulated as a two-stage optimization problem to efficiently
25
26 address the large-scale optimization problem with a high number of continuous and discrete
27
28 variables. The first stage solves the day-ahead scheduling of microgrids as a two-objective
29
30 optimization problem, using the min-max fuzzy method. The objectives are defined as the
31
32 minimization of the total operating cost minimization and the maximization of consumers' comfort
33
34 index. The second stage is devoted to the optimal DFR, carried out by the DSO, aimed at
35
36 minimizing the deviation from the optimal scheduling of microgrids, determined at the first stage.
37
38

39
40
41 The novelties of the paper can be briefly stated as follows:
42

- 43
44 • Proposing a two-stage optimization framework for scheduling of microgrids and DFR
- 45
46 • Considering smart homes and traditional loads in the model
- 47
48 • Solving the day-ahead scheduling problem of microgrids in the form of a two-objective
49
50 problem considering operation cost and consumers' comfort index
- 51
52 • Solving the DFR problem with regard to the optimal scheduling of microgrids
- 53
54 • Investigating the impact of different objective functions on smart homes' scheduling
- 55
56
57
58
59
60
61
62
63
64
65

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65

This paper organizes as follows. The system description is presented in Section 2. The mathematical problem formulation including the objective functions and corresponding constraints are addressed in Section 3. The algorithms and flowchart for solving the proposed model are presented in Section 4. Simulation results and the comprehensive discussion are addressed in Section 5 of this paper. The concluding remarks are presented in the last section of this paper.

14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65

Table 1. Comparison of this study with recent researches.

Refs.	Objectives	Mathematical Model	Problem Modeling		Multi-Stage	DFR	Home Appliances		Comfort Index	DR	EES	RER		Uncertainty
			Single-Objective	Multi-Objective			IoT	Fix				Wind	PV	
[10]	Profit	MILP	✓	✗	✗	✓	✗	✓	✗	✗	✓	✗	✓	✓
[7]	Cost Profit	MINLP	✓	✗	✗	✓	✗	✓	✗	✓	✗	✓	✓	✓
[14]	Cost	MINLP	✓	✗	✗	✓	✗	✓	✓	✓	✓	✓	✗	✓
[28]	Power Loss Voltage Deviation	MILP	✗	✓	✗	✓	✗	✓	✗	✓	✓	✗	✓	✗
[29]	Operation Cost Interruption Cost Switching Cost	MILP	✓	✗	✗	✓	✗	✓	✗	✗	✓	✗	✗	✗
[30]	ENS Power Loss	MINLP	✗	✓	✗	✓	✗	✓	✗	✗	✗	✗	✗	✗
[21]	Cost Comfort Index	MINLP	✗	✓	✗	✗	✓	✗	✓	✗	✓	✓	✓	✗
[19]	Cost	MILP	✓	✗	✗	✗	✓	✗	✓	✗	✓	✗	✓	✓
[20]	Cost	MILP	✓	✗	✗	✗	✓	✗	✗	✗	✓	✓	✓	✗
[18]	Cost PAR Comfort Index	MINLP	✓	✗	✗	✗	✓	✗	✓	✓	✓	✗	✓	✗
[31]	Cost	MILP	✓	✗	✗	✗	✓	✗	✓	✗	✓	✗	✓	✓
[32]	Cost	MILP	✓	✗	✗	✗	✓	✗	✗	✗	✓	✗	✓	✗
[33]	Power Unbalance	MINLP	✓	✗	✗	✗	✗	✓	✗	✗	✓	✓	✗	✗
[34]	Cost Comfort Index	MILP	✗	✓	✓	✗	✓	✗	✓	✓	✓	✓	✓	✗
[11]	Profit Fuzzy Rules	MILP	✗	✓	✗	✗	✗	✓	✗	✗	✓	✗	✓	✓
[12]	Cost	MILP	✓	✗	✓	✗	✗	✓	✗	✗	✓	✓	✓	✓
[9]	Forecast Error	MINLP	✓	✗	✗	✗	✗	✗	✗	✗	✓	✗	✓	✓
[35]	Cost	MILP	✓	✗	✗	✗	✗	✗	✓	✗	✓	✓	✓	✓
[36]	Cost Comfort Index	MINLP	✗	✓	✗	✗	✓	✗	✓	✓	✓	✓	✓	✓
[22]	Cost Thermal Comfort	MILP	✓	✗	✗	✗	✓	✗	✓	✗	✓	✗	✓	✓
[23]	Cost	MINLP	✓	✗	✗	✗	✗	✓	✗	✗	✗	✗	✓	✗

2- System description

The test system, used in this paper to assess the proposed model is the modified IEEE 118-bus system, comprising ten microgrids, depicted in Fig. 1. As this figure indicates, each microgrid supplies its load demand by utilizing RESs, including wind and solar power generation, non-renewable sources, including a gas-turbine, and also by transacting power with the upstream network. It is noteworthy that an electrical energy storage (EES) system has been used along with the renewable energy technologies. Moreover, 15 switches have been considered for the DFR, as depicted in Fig. 1 in red. Each microgrid serves both traditional load demand and smart homes, and the day-ahead scheduling is done, aimed at maximizing the smart homes' comfort index. The locations of smart homes in the microgrids are specified in green. The controllable loads of a smart home comprise a washing machine, a clothes dryer, a dishwasher, an iron, a microwave oven, a cooker, an electric kettle, and a toaster. In addition, fixed loads of each smart home relate to the cooling, heating, and lighting system. Every smart home is equipped with self-generation technologies, including a PV panel and an EES system to mitigate the amount of the bill and increase the system flexibility.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65




Fig. 1. The overview of the modified IEEE 118-bus distribution system.

3- Formulation

This section presents the mathematical formulation of the problem.

- Objective Functions

The objective functions of the first stage of the problem are defined as the minimization of the total operating cost and maximization of the consumers' comfort index, expressed in (1a) and (1b) respectively, in the service area of each microgrid. It should be noted that the resulting multi-objective problem is solved by employing the min-max fuzzy method [37]. In this regard, expression (1c) indicates the membership function, assigned to each objective.

The objective function of the second stage is presented in Eq. (1d), which is to minimize operating costs of the main grid and the penalty of deviating from microgrids scheduling. The objective function indicates that the network will be penalized if fails to satisfy the requested power exchange of the microgrids. $P_{i,j,t,s}^{line,req}$ is the requested power exchange by the microgrid, while $P_{i,j,t,s}^{line}$ is the power exchange finalized by the DSO. $\pi_{mg}^{penalty}$ is the penalty cost for deviating from the microgrids scheduling. It is noteworthy that the objective function of this stage is solved from the DSO point of view.

$$\min \sum_{s=1}^S \rho_s \sum_{mg=1}^{MG} Cost_{mg,s} \quad (1a)$$

$$\max \sum_{s=1}^S \rho_s \sum_{mg=1}^{MG} Comfort_{mg,s} \quad (1b)$$

$$\max \mu \leq \begin{cases} \mu^1 = \frac{Cost^{\max} - Cost^{opt}}{Cost^{\max} - Cost^{\min}} \\ \mu^2 = \frac{Comfort^{opt} - Comfort^{\min}}{Comfort^{\max} - Comfort^{\min}} \end{cases} \quad (1c)$$

$$\min \sum_{s=1}^S \rho_s \left[\sum_{t=1}^T \sum_{i \in D_{mg}^+} \left(\sum_{g \in D_i^g} C_{g,t,s}^{gen} + \sum_{w \in D_i^w} C_{w,t,s}^{wind} + \sum_{pv \in D_i^{pv}} C_{pv,t,s}^{solar} \right) + \sum_{t=1}^T \sum_{st \in D_t^{st}} \pi_t^e P_{st,t,s}^{sub} \Delta t \right. \\ \left. \sum_{mg=1}^{MG} \pi_{mg}^{penalty} \sum_{t=1}^T \sum_{(i,j) \in \{D_{mg,t}^{j+}, D_{mg,t}^{j-}\}} |P_{i,j,t,s}^{line} - P_{i,j,t,s}^{line,req}| \Delta t \right] \quad (1d)$$

- **Power Flow**

The linearized AC power flow (ACPF) relationships, used in this paper are represented in (2a)-(2o) [38]. The conductance and susceptance of the feeder are calculated as (2a) and (2b) respectively. Eqs. (2c) and (2d) represent the active and reactive power flow of lines, as functions of voltage magnitude and angle. The active and reaction power injection of each bus to the connected branches are determined by using Eqs. (2e) and (2f), respectively. Eq. (2g) shows the apparent power flow of each line as a function of the active and reactive power flows and the average power factor of the sending and receiving buses. Inequality (2h) applies the security constraint, relating to the minimum and maximum power flow of lines. The nodal active and reactive power balance equations are stated in (2i) and (2j) respectively, and constraints (2k) and (2l) limit the voltage magnitude and voltage angle within the permitted range respectively. The system's power losses are also calculated by using relationships (2m)-(2o). In this respect, Eq. (2m) shows that power flow of each line would be specified with respect to the operating point of that line. Constraint (2n) indicates the operating point limitation of each line. Finally, Eq. (2o) gives the power losses of each line.

$$G_{i,i}^{line} = \frac{r_{i,j}}{r_{i,j}^2 + x_{i,j}^2} \quad (2a)$$

$$B_{i,i}^{line} = \frac{x_{i,j}}{r_{i,j}^2 + x_{i,j}^2} \quad (2b)$$

$$G_{i,j}^{line} (V_{i,t,s}^{bus} - V_{j,t,s}^{bus}) + B_{i,j}^{line} (\theta_{i,t,s}^{bus} - \theta_{j,t,s}^{bus}) + \frac{P_{i,j,t,s}^{loss}}{2} - M(1 - I_{l,t,s}^{flow}) \leq P_{i,j,t,s}^{line} \leq \quad (2c)$$

$$G_{i,j}^{line} (V_{i,t,s}^{bus} - V_{j,t,s}^{bus}) + B_{i,j}^{line} (\theta_{i,t,s}^{bus} - \theta_{j,t,s}^{bus}) + \frac{P_{i,j,t,s}^{loss}}{2} + M(1 - I_{l,t,s}^{flow}) \leq Q_{i,j,t,s}^{line} \leq \quad (2d)$$

$$B_{i,j}^{line} (V_{i,t,s}^{bus} - V_{j,t,s}^{bus}) - G_{i,j}^{line} (\theta_{i,t,s}^{bus} - \theta_{j,t,s}^{bus}) - M - I_{l,t,s}^{flow} \leq Q_{i,j,t,s}^{line} \leq \quad (2d)$$

$$P_{i,t,s}^{inj} = \sum_{j(j \neq i)}^J P_{i,j,t,s}^{line} \quad (2e)$$

$$Q_{i,t,s}^{inj} = \sum_{j(j \neq i)}^J Q_{i,j,t,s}^{line} \quad (2f)$$

$$S_{i,j,t,s}^{line} = P_{i,j,t,s}^{line} + \xi_{i,j}^{line} Q_{i,j,t,s}^{line} \quad (2g)$$

$$-S_{i,j}^{max} I_{l,t,s}^{flow} \leq S_{i,j,t,s}^{line} \leq S_{i,j}^{max} I_{l,t,s}^{flow} \quad (2h)$$

$$\sum_{st \in D_i^{st}} P_{st,t,s}^{sub} + \sum_{g \in D_i^g} P_{g,t,s}^{gen} + \sum_{w \in D_i^w} (P_{w,t,s}^{wind} + P_{w,t,s}^{dch} - P_{w,t,s}^{ch}) + \sum_{pv \in D_i^{pv}} (P_{pv,t,s}^{solar} + P_{pv,t,s}^{dch} - P_{pv,t,s}^{ch}) = P_{i,t,s}^{inj} + P_{i,t,s}^{Demand} \quad (2i)$$

$$\sum_{st \in D_i^{st}} Q_{st,t,s}^{sub} + \sum_{g \in D_i^g} Q_{g,t,s}^{gen} = Q_{i,t,s}^{inj} + Q_{i,t,s}^{Demand} \quad (2j)$$

$$V_{i,t,s}^{min} \leq V_{i,t,s} \leq V_{i,t,s}^{max} \quad (2k)$$

$$\theta_{i,t,s}^{min} \leq \theta_{i,t,s} \leq \theta_{i,t,s}^{max} \quad (2l)$$

$$|S_{i,j,t,s}^{line}| = \sum_b \alpha_{i,j,t,s,b} S_b \quad (2m)$$

$$0 \leq \sum_{b=1}^B \alpha_{i,j,t,s,b} \leq 1 \quad (2n)$$

$$P_{i,j,t,s}^{loss} = r_{i,j} \sum_b \alpha_{i,j,t,s,b} S_b^2 \quad (2o)$$

• DFR

Constraints (3a)-(3c) guarantee the radiality of the network during DFR. Constraint (3a) determines the direction of power flow in the active lines (present in operation). $I_{l(i,j),t}^{flow}$ is a binary variable that determines the presence/absence of each line at time t . Constraint (3b) states that each bus can receive power from only one line. Constraint (3c) prevents the injection of power into the slack bus. Finally, constraint (34) limits the number of switches during operation horizon [39].

$$I_{i,j,t,s}^{flow} + I_{j,i,t,s}^{flow} = I_{l(i,j),t,s}^{flow} \quad (3a)$$

$$\sum_{j(j \neq i)}^J I_{j,i,t,s}^{flow} = 1 \quad (3b)$$

$$\sum_{j(j \neq i)}^J I_{j,i \in D_i^{st},t,s}^{flow} = 0 \quad (3c)$$

$$\sum_{t=1}^T \sum_{l=1}^L |I_{l,t,s}^{flow} - I_{l,t-1,s}^{flow}| \leq N^{sw} \quad (3d)$$

• Appliances

As mentioned above, each microgrid includes a number of smart homes and it operates considering traditional loads and smart homes. In this respect, Eqs. (4a)-(4p) represent the relationships, required to model the operation of home appliances [40]. The load demand of each home includes

two load categories as fixed and schedulable loads, shown in (4a). The hourly consumption of each appliance is stated in (4b), while (4c) shows that the operation time of each appliance must be equal to the corresponding length of operation time (LOT). Besides, constraint (4d) states that each appliance should be activated only in its utilization time range (UTR) interval. Constraint (4e) indicates that the appliance operation is uninterruptable. It should be noted that some appliances have dependent operation. For example, first, the WM should work and after that the SD starts working. The operation of such appliances has been modeled by relationships (4f)-(4h). Constraint (4f) ensures the proper operation of each appliance. Constraint (4g) models the limitation of binary variable $H_{i,t,s,n,h}$. As constraint (4h) states, each dependent appliance should be turned on after the operation of the independent appliance is finished. Constraints (4i)-(4k) are proposed to ensure the permitted time intervals, required between the operations of dependent appliances. The consumer's comfort index is calculated in Eq. (4l) as a function of the comfort index and value factor of each appliance. Eqs. (4m) and (4n) are used to determine the user's convenience level (UCL) of the appliances and comfort level of all smart homes is calculated as (4o). As can be seen, in Eq. (4n), two exponential functions are used to determine UCL. This equation states that if the appliance activation time is in the consumers' preferred range, the UCL value will be equal to 1, and if the appliance activation time is outside the consumers' preferred range, the UCL value will decrease with a certain slope. Where, β_n denotes damping coefficient of preferred convenience curve.

$$P_{i,t,s}^{demand} = P_{i,t,s}^{fix} + \sum_{n=1}^N P_{i,t,s,n}^{schedule} \quad (4a)$$

$$P_{i,t,s,n}^{schedule} = \frac{EEC_n I_{i,t,s,n}}{LOT_n} \quad (4b)$$

$$\sum_{t \in UTR^n} I_{i,t,s,n}^{appliance} = LOT_n \quad (4c)$$

$$\sum_{t \notin UTR^n} I_{i,t,s,n}^{appliance} = 0 \quad (4d)$$

$$\sum_{t \in UTR^n} \left| I_{i,t,s,n}^{appliance} - I_{i,t-1,s,n}^{appliance} \right| \leq 2 \quad (4e)$$

$$\sum_{t \in UTR^n} I_{i,t,s,n}^{appliance} - LOT_n = \sum_h I_{i,t,s,n,h}^{step} \delta_h \quad (4f)$$

$$\sum_h I_{i,t,s,n,h}^{step} = 1 \quad (4g)$$

$$I_{i,t,s,m}^{appliance} \leq I_{i,t,s,n,h=H}^{step} \quad (4h)$$

$$I_{i,t,s,n}^{turn-on} - I_{i,t,s,n}^{turn-off} = I_{i,t,s,n} - I_{i,t-1,s,n} \quad (4i)$$

$$0 \leq I_{i,t,s,n}^{turn-on} + I_{i,t,s,n}^{turn-off} \leq 1 \quad (4j)$$

$$I_{i,t,s,m}^{turn-on} - I_{i,t,s,n}^{turn-off} \leq T_{n,m}^{gap} \quad (4k)$$

$$UCL_{i,s} = \frac{\sum_{n=1}^N w_n CV_{i,s,n}}{\sum_{n=1}^N w_n LOT_n} \quad (4l)$$

$$CV_{i,s,n} = \sum_{t=1}^T I_{i,t,s,m}^{appliance} PCV_{t,n} \quad (4m)$$

$$PCV_{t,n} = \begin{cases} 1 & , t \in PTR \\ \beta_n e^{t-t_n^{start}} & , t < t_n^{start} \\ \beta_n e^{t_n^{end}-t} & , t > t_n^{end} \end{cases} \quad (4n)$$

$$Comfort_{mg,s} = \sum_{i \in D_{mg}^i} UCL_{i,s} \quad (4o)$$

• Generation Units

Relationships (5a)-(5h) relate to the power generation by DERs and their associated operating cost.

In this regard, Eq. (5a) shows the hourly power generation equation of the wind turbine, which is a function of the hourly wind speed and turbine characteristics [41]. The power, generated by the PV panel is in accordance with Eq. (5b) as a function of the hourly solar [34]. Noted that the converter efficiency (η_{pv}^{conv}) is considered to be 95%. As Eq. (5c) shows, the power, generated by the MT is a function of the input gas and turbine efficiency. The constraints of active and reactive power generation of the MT are represented in (5d) and (5e) respectively. The operating costs of the MTs, wind turbines, and PV panels are stated in Eqs. (5f)-(5h) respectively. The total operating cost of each microgrid is also calculated as Eq. (5i).

$$P_{w,t,s}^{wind} = \begin{cases} 0, & v_{w,t,s} < v_i, v_{w,t,s} > v_o \\ P_w^r \frac{v_{w,t,s} - v_i}{v_r - v_i}, & v_i \leq v_{w,t,s} < v_r \\ P_w^r, & v_r \leq v_{w,t,s} < v_o \end{cases} \quad (5a)$$

$$P_{pv,t,s}^{solar} = \frac{G_{pv,t,s}}{G_{std}} P_{pv}^r \eta_{pv}^{conv} \quad (5b)$$

$$P_{g,t,s}^{gen} = G_{g,t,s}^{gen} \eta^{gen} \quad (5c)$$

$$P_g^{\min} I_{g,t,s}^{gen} \leq P_{g,t,s}^{gen} \leq P_g^{\max} I_{g,t,s}^{gen} \quad (5d)$$

$$Q_g^{\min} I_{g,t,s}^{gen} \leq Q_{g,t,s}^{gen} \leq Q_g^{\max} I_{g,t,s}^{gen} \quad (5e)$$

$$C_{g,t,s}^{gen} = \pi_g^{gen} P_{g,t,s}^{gen} \Delta t \quad (5f)$$

$$C_{w,t,s}^{wind} = \pi_w^{wind} P_{w,t,s}^{wind} \Delta t \quad (5g)$$

$$C_{pv,t,s}^{solar} = \pi_{pv}^{solar} P_{pv,t,s}^{solar} \Delta t \quad (5h)$$

$$Cost_{mg,s} = \sum_{t=1}^T \sum_{i \in D_{mg}^i} \left(\sum_{g \in D_g^s} C_{g,t,s}^{gen} + \sum_{w \in D_w^s} C_{w,t,s}^{wind} + \sum_{pv \in D_{pv}^s} C_{pv,t,s}^{solar} \right) + \sum_{t=1}^T \left[\pi_t^e \left(\sum_{(i,j) \in D_{mg,t}^{j+}} P_{i,j,t,s}^{line} - \sum_{(i,j) \in D_{mg,t}^{j-}} P_{i,j,t,s}^{line} \right) \Delta t \right] \quad (5i)$$

• Network' EES system

The renewable power generation units are all equipped with an EES system. In this respect, relationships (6a)-(6h) show the operation model of the EES systems, installed along with the wind turbines. Eq. (6a) indicates that the energy, available in the EES system at each hour is a function of the energy, stored in the system in the previous hour and the charging/discharging power at the present hour. It should be noted that Δt is time step and its value is equal to 1 hour. Constraint (6b) shows the initial amount of energy, stored in the EES system at the beginning of the scheduling period. The limitations on the energy, stored in the system has also been stated in (6c), while constraints (6d) and (6e) force the charging and discharging rates to be within the permitted range respectively. As constraint (6f) shows, the EES system is obliged to operate in either charging or discharging mode. Furthermore, according to constraint (6g), the amount of energy that must be available in the EES system at the end of the scheduling period should be equal or greater than the initial amount [42].

$$E_{w,t,s} = E_{w,t-1,s} + \left(P_{w,t,s}^{ch} \eta^{ch} - \frac{P_{w,t,s}^{dch}}{\eta^{dch}} \right) \Delta t \quad (6a)$$

$$E_{w,t=0,s} = E_w^0 \quad (6b)$$

$$E_w^{\min} \leq E_{w,t,s} \leq E_w^{\max} \quad (6c)$$

$$0 \leq P_{w,t,s}^{ch} \leq P_w^{ch,max} I_{w,t,s}^{ch} \quad (6d)$$

$$0 \leq P_{w,t,s}^{dch} \leq P_w^{dch,max} I_{w,t,s}^{dch} \quad (6e)$$

$$0 \leq I_{w,t,s}^{ch} + I_{w,t,s}^{dch} \leq 1 \quad (6f)$$

$$E_{w,t=24,s} \geq E_w^0 \quad (6g)$$

- **Smart home' EES system**

Relationships (7a)-(7i) indicate the operation model of the EES systems, installed next to PV panels [43]. Constraint (7a) states the limitation of the amount of energy, stored in the EES system. Constraints (7b) and (7c) show the calculation of the charging power and discharging power respectively, which are the function of the respective efficiencies and the energy, available in the EES system. The charging power and discharging power are limited as shown in (7d) and (7e) respectively. The conflict between the charging and discharging modes is avoided by using constraint (7f). The energy, stored in the EES system at each hour is determined by utilizing relationship (7g). The constraints of the initial and final values of the energy, stored in the EES system are in accordance with (7h). Condition (7i) states that the energy level of EES systems located in smart homes must be equal to or greater than the initial energy level at the last hour of scheduling.

$$E_{pv}^{\min} \leq E_{pv,t,s} \leq E_{pv}^{\max} \quad (7a)$$

$$P_{pv,t,s}^{ch} \Delta t \leq E_{pv}^{\max} \frac{(1 - E_{pv,t-1,s})}{(1 - \eta^{ch}) \eta^{conv}} \quad (7b)$$

$$P_{pv,t,s}^{dch} \Delta t \leq E_{pv}^{\max} (E_{pv,t-1,s} - 1) (1 - \eta^{dch}) \eta^{conv} \quad (7c)$$

$$P_{pv,t,s}^{ch} \Delta t \leq \frac{E^{ch,conv}}{\eta^{conv}} I_{pv,t,s}^{ch} \quad (7d)$$

$$P_{pv,t,s}^{dch} \Delta t \leq \frac{E^{dch,conv}}{\eta^{conv}} I_{pv,t,s}^{dch} \quad (7e)$$

$$0 \leq I_{pv,t,s}^{ch} + I_{pv,t,s}^{dch} \leq 1 \quad (7f)$$

$$E_{pv,t,s} = E_{pv,t-1,s} - \frac{\Delta t}{E_{pv}^{\max}} \left[\frac{P_{pv,t,s}^{dch}}{(1-\eta^{dch})\eta^{dch,conv}} + P_{pv,t,s}^{ch} (1-\eta^{ch})\eta^{ch,conv} \right] \quad (7g)$$

$$E_{pv,t=0,s} = E_{pv}^0 \quad (7h)$$

$$E_{pv,t=24,s} \geq E_{pv}^0 \quad (7i)$$

• Uncertainty modeling process

The uncertainties due to the load demand, market price, and renewable power generation have been applied to the problem to obtain a more realistic solution. In this regard, first, 1000 scenarios are generated for each uncertain parameter by the probability distribution functions (PDFs), using the Gaussian PDF for the load demand, market price and solar irradiance, and the Weibull PDF for the wind speed. Gaussian PDF is presented in Eq. (8a). μ_x and σ_x denote the mean and standard deviation, respectively; Δx_i denotes the error of the load prediction. The values of parameters μ_x and σ_x are considered 0 and 0.3, respectively. Weibull PDF is presented in Eq. (8b). λ and k denote the scale and shape parameters, respectively [44]. The values of parameters λ and k are considered 1 and 1.5, respectively.

$$f(\Delta x_i; \mu_x, \sigma_x^2) = \frac{1}{\sqrt{2\pi\sigma_x^2}} \exp \left[-\frac{(\Delta x_i - \mu_x)^2}{2\sigma_x^2} \right] \quad (8a)$$

$$f(x; \lambda, k) = \begin{cases} \frac{k}{\lambda} \left(\frac{x}{\lambda} \right)^{k-1} e^{-\left(\frac{x}{\lambda} \right)^k}, & x \geq 0 \\ 0, & x < 0 \end{cases} \quad (8b)$$

Afterward, the number of scenarios is reduced by employing the SCENRED2 in GAMS [45], to alleviate the computational load of the problem. It should be noted that SCENRED2 is a fundamental update of the well-known scenario reduction software SCENRED. SCENRED is a tool for reducing the number of scenarios that performs the scenario reduction process by one of the fast backward, mix of fast backward/forward and mix of fast backward/backward algorithms.

1
2
3
4 • **Multi-scenario modelling**
5

6
7 In this subsection, the process of multi-scenario modeling is shown [46]. To this end, each
8
9 continuous PDF is discretized in order to form a set of finite states. It should be mentioned that an
10
11 occurrence probability is assigned to each state. discrete sets related to different parameters
12
13 forecasting errors are shown in (9a)-(9d). e_D^i denotes the error related to the i th state, ρ_D^i denotes
14
15 the probability of i th state, and n denotes the number of states of the discrete set. Discrete sets of
16
17 other uncertain parameters are determined in the same way. Note that the probabilities of states
18
19 are subject to constraint (9e).
20
21
22

23
24
$$\delta_D = \{(e_D^1, \rho_D^1), (e_D^2, \rho_D^2), \dots, (e_D^n, \rho_D^n)\}$$
 (9a)
25

26
27
$$\delta_P = \{(e_P^1, \rho_P^1), (e_P^2, \rho_P^2), \dots, (e_P^k, \rho_P^k)\}$$
 (9b)
28

29
30
$$\delta_W = \{(e_W^1, \rho_W^1), (e_W^2, \rho_W^2), \dots, (e_W^m, \rho_W^m)\}$$
 (9c)
31

32
33
$$\delta_{PV} = \{(e_{PV}^1, \rho_{PV}^1), (e_{PV}^2, \rho_{PV}^2), \dots, (e_{PV}^q, \rho_{PV}^q)\}$$
 (9d)
34

35
36
$$\sum_{i=1}^n \rho_D^i = \sum_{i=1}^k \rho_P^i = \sum_{i=1}^m \rho_W^i = \sum_{i=1}^q \rho_{PV}^i = 1$$
 (9e)
37
38
39

40 The discrete sets obtained from Eqs. (9a) - (9d) are used to form a set of scenarios that indicate the
41
42 possible deviations from the load, price, wind, and irradiance forecasted values. Each scenario has
43
44 a probability (ρ_s^i), which is equal to the product of the probabilities of the states related to that
45
46 scenario, as illustrated in Eq. (9f). Also, according to Eq. (9g) the total number of obtained
47
48 scenarios is equal to the product of the number of states in each discrete set.
49
50
51

52
53
$$\sum_{i=1}^S \rho_s^i = \sum_{i=1}^S \rho_D^i \rho_P^i \rho_W^i \rho_{PV}^i = 1$$
 (9f)
54
55

56
$$S = n \times m \times q \times k$$
 (9g)
57
58
59
60
61
62
63
64
65

4- Methodology

Fig. 2 depicts the flowchart of the proposed model. As can be observed, the scenarios are generated by PDFs and then, they are reduced by using the SCENRED2 in GAMS. After that, at the first stage, the operation problem would be solved from the viewpoint of each microgrid, aimed at optimizing the operating cost and consumers' comfort index. It should be noted that the problem of microgrid scheduling can be solved as a single-objective or two-objective problem. In the case of choosing two-objective scheduling, a pay-off table will be formed to solve the two-objective problem of microgrids scheduling. The payoff table in multi-objective programming provides the individual optimal of the objective functions (in the diagonal). The goal of forming a payoff table is to help formulate the constraint model in the next task (membership functions), by determining the lower and upper bounds for the objective functions. A membership function is a curve that defines how each point in the input space is mapped to a membership value (or degree of membership) between 0 and 1. At the end of the first stage, the results, relating to the microgrids operation, including the new load demand curve, besides the hourly power transaction, are fixed at their optimal values and delivered to the DSO. At second stage, the DSO would be able to evaluate the possibility of the obtained scheduling of microgrids. It is also noted that the system topology can be either fixed or reconfigured at this stage. If the system is reconfigured, it is carried out, aimed at minimizing the deviation from the optimal scheduling of microgrids, determined at the first stage. If the hourly scheduling of any microgrid is not possible to implement, corrective signals (optimality cuts) would be generated by the DSO and sent to the respective microgrid. These signals are added to the problem as new constraints and the scheduling continues until satisfying the stopping criterion. Table 2 presents a pseudo-code that shows the solution process of the proposed algorithm.

Table 2. Pseudo-code required to execute the proposed algorithm.

<p>Step 1:</p>	<p>Solve microgrids day-ahead scheduling in the form of:</p> $MO \begin{cases} \min OF_1 = \sum_{mg=1}^{MG} Cost_{mg} \\ \max OF_2 = \sum_{mg=1}^{MG} Comfort_{mg} \end{cases}$ <p><i>s.t.</i> (2a)-(2o), (4a)-(4o), (5a)-(5i), (6a)-(6g), (7a)-(7i)</p>
<p>Step 2:</p>	<p>Send microgrids' day-ahead scheduling to the DSO and convert the distribution system to the multi-zone area network.</p>
<p>Step 3:</p>	<p>Evaluation operation results of microgrids by DSO with/without implementing DFR in the form of: Min Eq. (1d) <i>s.t.</i> (2a)-(2o), (3a)-(3d), (4a)-(4o), (5a)-(5i), (6a)-(6g), (7a)-(7i)</p>
<p>Step 4:</p>	<p>Check power transaction violations of each microgrid: For each line, do: If positive error happens, Then: Define lower limit for the line. Active positive error flag. Else If negative error happens, Then: Define upper limit for the line. Active negative error flag. Else: Stop and return results. End End</p>
<p>Step 5:</p>	<p>For each positive error, Do: Add a cut to limit the lower level of line. End For each negative error, Do: Add a cut to limit the upper level of line. End</p>
<p>Step 6:</p>	<p>Define cuts as new constraints for the scheduling problem in each iteration.</p>
<p>Step 7:</p>	<p>Go to step 1.</p>




Fig. 2. The flowchart of proposed model.


5- Simulation results

5-1- Data


The presented problem is investigated through four case studies, indicated in Table 3. As can be seen from this table, the effect of fixed and reconfigurable topologies as well as different objective functions on microgrid scheduling will be investigated. The generated scenarios for load demand, market price, solar radiation and wind speed are presented in Figs. 3a-3d, respectively. The scenarios presented in Fig. 3a are related to the fixed load of smart homes. It should be noted that the load of schedulable appliances will also be added to this load (depends on the activation time of appliances). As mentioned earlier, in order to reduce the computational burden, the number of scenarios of each uncertain parameter has been reduced to 10 by utilizing the SCENRED2 in GAMS, as illustrated in Figs. 4a-4d. The generated and reduced scenarios for traditional home demand are presented in Figs. 5a and 5b, respectively. The data of the modified IEEE 118-bus system are available in [47]. Furthermore, Tables 4 and 5 represent the data to model the microgrids and smart homes. Finally, the data required to simulate the problem are presented in Table 6.

Table 3. Case studies and their corresponding assumptions.

Case no.	Topology		Objective function	
	Fixed	Reconfigurable	Single-objective	Two-objective
1	✓	✗	✓	✗
2	✗	✓	✓	✗
3	✓	✗	✗	✓
4	✗	✓	✗	✓




(a) Electrical load




(b) Electricity price

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65




(c) Irradiance




(d) Wind speed


Fig. 3. Generated scenarios for uncertain parameters.




(a) Electrical load



(b) Electricity price




(c) Irradiance




(d) Wind speed

Fig. 4. Reduced scenarios of uncertain parameters.



(a) Generated scenarios



(b) Reduced scenarios

Fig. 5. Traditional home load scenarios

Table 4. Input data of microgrids.

Microgrids No.	Number of Buses	Total Number of Customers	Number of Smart Homes	Capacity of DERs (kW)	
				Gas Turbine	RER
1	6	63	29	300	-
2	10	289	112	1000	1700
3	9	263	89	1200	-
4	13	791	110	2300	1000
5	8	314	188	900	1000
6	12	603	178	2600	500
7	8	235	78	-	2200
8	10	299	109	-	1600
9	9	605	107	2300	-
10	5	107	43	300	-

Table 5. Smart homes' appliance scheduling data.

Appliance	UTR	PTR	LOT (h)	EEC (kWh)
Washing Machine	9:00-17:00	10:00-11:00	2	1
Dishwasher	12:00-19:00	15:00-16:00	2	1.4
Clothes Dryer	11:00-19:00	12:00-13:00	1	1.8
Iron	5:00-9:00	6:00-7:00	1	1.1
Vacuum Cleaner	9:00-19:00	11:00-14:00	1	0.65
Microwave	11:00-16:00	13:00-14:00	1	0.9
Rice Cooker	10:00-15:00	12:00-13:00	2	0.6
Electric Kettle	6:00-10:00	7:00-8:00	1	1
Toaster	6:00-10:00	7:00-8:00	1	0.8

Table 6. Data required for simulation.

Parameter	Value	Parameter	Value
$\pi_i^{e,\max}$	18 Cent	π_g^{gen}	6 Cent
M	1e7	$v_i / v_r / v_o$	2 / 14 / 25 m/s
N^{sw}	40	G_{std}	1000 W/m ²
η^{ch} / η^{dch}	95%	E_w^0 / E_{pv}^0	20%
$\eta^{conv} / \eta_{pv}^{conv}$	95%	$E_w^{\min} / E_{pv}^{\min}$	20%
Δt	1 h	$E_w^{\max} / E_{pv}^{\max}$	100%
$V_{i,t,s}^{\min} / V_{i,t,s}^{\max}$	0.9 / 1.1 p.u.	$P_w^{ch,\max} / P_{pv}^{ch,\max}$	40%
$\theta_{i,t,s}^{\min} / \theta_{i,t,s}^{\max}$	-3.14 / 3.14 rad	$P_w^{dch,\max} / P_{pv}^{dch,\max}$	40%
T_{n_1, n_2}^{gap}	1 h	η^{gen}	65%

β_n	1.1	$\pi_w^{wind} / \pi_{pv}^{solar}$	3 Cent
-----------	-----	-----------------------------------	--------

Table 7 includes the results, obtained from solving the problem for the four case studies. As can be observed, the first iteration is associated with the best solution, since the scheduling problem of each microgrid is solved from its own point of view. Accordingly, the highest error also relates to this iteration. As the number of iterations increases, the error and the number of optimality cuts reduce, since the scheduling of microgrids would be more appropriately carried out by receiving the corrective signals from the DSO. It can be seen that the error and the number of optimality cuts reach zero in the last iteration. Thus, the obtained scheduling can be implemented. Errors are the difference between microgrids scheduling and DSO scheduling and are calculated in kW. For example, if microgrid 4 has a demand of 100 kW at 4 pm and DSO is only able to supply 60 kW of this demand due to network limitations, the error value will be equal to 40 kW. It should be noted that the value provided for the error in each iteration is the sum of the errors of all the optimality cuts in that iteration.

The comparison made between Cases 2 & 4 and Cases 1 & 3 reveals that the DFR would lead to more reduced operating cost and enhanced consumers' comfort index. As Table 7 shows, operating cost in Case 2 decreased by 10.17% compared to Case 1, which is due to the implementation of DFR. The results also illustrate that the comfort index has increased by 2.9% compared to Case 1. Moreover, the deviation from the optimum scheduling of microgrids will be lower in Cases 2 and 4. This is due to the fact that the DSO reconfigures the system, aimed at minimizing the deviation from the optimum scheduling of microgrids. It can also be observed that the minimum operating cost relates to Case 2, as the objective in this case is minimizing the operating cost with the DFR possibility. A comparison of Cases 2 and 4 indicates that a 22.3% increase in the consumers' comfort index in case 4 has resulted in an increase of about 6.1% in operating costs.

Table 8 shows the final operation results, comprising the operating cost, consumers' comfort index, the amount of power transaction, the number of optimality cuts for each case and each microgrid. The obtained results also indicate that the DFR would more affect the operating cost of the microgrid than the comfort index. For instance, the operating cost of microgrid 2 in the first case study is 60.93 \$/day, while in Case 2 with the DFR, microgrid 2 can make a profit by -1269.69 \$/day through selling power to other microgrids. It is noted that this issue is adverse for some microgrids like microgrid 9 and microgrid 10, where their operating costs have relatively increased. In general, it can be concluded that the impact of the DFR on the operation of each microgrid is substantial.

Table 9 represents the hourly topology of the system with respect to the open switches for Case 2 and Case 4. It is worth noting that the system topology changes each hour as the state of open switches changes. The maximum number of switching is limited to 40 to avoid the amortization of switches and any noise in the system. Figs. 6a and 6b depict the number of switch changes per hour in Cases 2 and 4, respectively. As can be seen, the network topology in Case 4 has changed more than Case 2, which is due to the different objective functions of these cases. Finally, the obtained topologies for the network at different times of the day in Case 4 are presented in Figs. 7a-7d. It should be noted that the red dashed lines indicate the open switches. As can be seen, the network topology has changed at different times of the day in order to satisfy the objective functions.

Table 7. The obtained results of each case study.

Iter.	Operation cost		Comfort level		Error (kW)	Number of cuts	
	Obtained (\$/day)	Deviation from optimum point (%)	Obtained (%)	Deviation from optimum point (%)		Positive cuts	Negative cuts
Case study (1)							
1	8931.00	0	78.44	1.10	144150.7	230	170
2	10471.90	17.25	77.93	1.75	16040.30	54	37

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65

3	10783.11	20.74	77.57	2.20	1130.78	18	5
4	10810.99	21.05	79.14	0.22	163.30	12	2
5	10815.66	21.10	79.32	0	66.90	9	0
6	10854.16	21.53	78.39	1.17	0	0	0
Case study (2)							
1	8929.41	0	80.05	2.92	75140.79	161	129
2	9431.08	5.62	80.04	2.93	23362.21	109	48
3	9573.56	7.21	80.14	2.81	7482.10	56	14
4	9583.94	7.33	80.07	2.90	1604.45	39	0
5	9589.40	7.39	82.03	0.52	1492.61	36	3
6	9593.53	7.44	82.46	0	1195.35	15	1
7	9664.65	8.23	81.46	1.21	532.62	7	3
8	9691.12	8.53	81.02	1.75	151.62	4	2
9	9750.43	9.19	80.73	2.10	0	0	0
Case study (3)							
1	10854.16	0	100	0	109612.4	170	146
2	11007.72	1.41	99.64	0.36	28675.33	50	39
3	11365.40	4.71	98.98	1.02	2798.40	12	9
4	11409.96	5.12	98.72	1.28	852.51	10	3
5	11437.25	5.37	98.68	1.32	432.22	7	11
6	11459.97	5.58	98.61	1.39	110.62	3	1
7	11468.40	5.66	98.58	1.42	0	0	0
Case study (4)							
1	9750.43	0	100	0	57097.04	122	108
2	10095.22	3.54	99.29	0.71	16774.64	68	36
3	10181.42	4.42	99.11	0.89	5179.51	43	23
4	10223.76	4.85	99.02	0.98	2516.33	13	11
5	10296.37	5.60	98.95	1.05	723.18	7	6
6	10308.65	5.73	98.87	1.13	529.11	9	5
7	10339.66	6.04	98.81	1.19	171.44	1	7
8	10353.82	6.19	98.76	1.24	0	0	0


14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65

Table 8. The obtained results of each microgrid in different case studies.


Case (1)							Case (2)						
Microgrid No.	OC (\$/day)	Comfort index (%)	Number of cuts		Purchased energy (kWh)	Sold energy (kWh)	Microgrid No.	OC (\$/day)	Comfort index (%)	Number of cuts		Purchased energy (kWh)	Sold energy (kWh)
			Positive Cuts	Negative Cuts						Positive Cuts	Negative Cuts		
1	320.62	78.62	0	0	880.61	946.47	1	420.80	71.28	21	0	1899.70	213.47
2	60.93	76.76	72	5	0	5869.38	2	-1269.69	85.78	67	41	0	27740.92
3	1184.59	76.76	31	30	3567.89	5889.88	3	1248.46	78.53	65	24	3516.02	5131.45
4	4255.62	80.39	23	49	10790.29	2318.67	4	4641.50	76.76	29	38	18123.97	0
5	226.80	78.53	2	23	816.95	6929.32	5	482.22	78.62	3	17	956.86	3447.15
6	2931.98	76.67	34	41	5600.00	5426.45	6	2747.60	83.92	42	15	7471.34	9314.39
7	-1881.26	80.39	51	2	0	23834.44	7	-1948.29	85.78	95	12	21.32	25552.92
8	7.43	80.29	50	21	0	6096.59	8	-465.79	84.02	38	10	76.98	11519.18
9	3071.02	78.62	42	24	8398.55	2431.51	9	3208.29	84.02	27	16	9836.94	1613.55
10	676.43	76.86	18	19	2586.09	1.36	10	685.33	78.62	40	27	2942.37	0
Case (3)							Case (4)						
Microgrid No.	OC (\$/day)	Comfort index (%)	Positive Cuts	Negative Cuts	Purchased energy (kWh)	Sold energy (kWh)	Microgrid No.	OC (\$/day)	Comfort index (%)	Positive Cuts	Negative Cuts	Purchased energy (kWh)	Sold energy (kWh)
1	356.18	100	0	0	1861.36	425.56	1	367.81	100	0	0	1915.43	505.80
2	91.40	100	72	3	0	5853.17	2	-1227.00	100	55	31	0	27884.75
3	1239.30	96.47	28	28	3676.66	5615.80	3	1320.45	100	36	38	3236.62	4215.25
4	4380.45	100	11	49	11046.38	1686.81	4	4714.91	100	26	29	22091.07	0
5	366.93	96.47	7	23	1171.48	5761.10	5	432.37	96.47	10	13	1092.13	4965.08
6	3011.17	100	16	45	5600.00	5426.45	6	2898.00	98.23	37	28	7475.44	7256.73
7	-1830.49	96.47	32	4	0	23220.04	7	-1754.50	100.00	37	14	0	24659.02
8	17.37	100	52	12	0	6037.37	8	-413.77	98.23	34	8	273.77	11327.56
9	3135.20	96.47	20	24	9441.12	2236.26	9	3301.20	94.70	14	13	10716.22	1300.86
10	700.89	100	14	21	3148.64	0	10	714.36	100	14	22	3395.86	0

Table 9. The obtained topology in cases 2 and 4.

Hour	Open Switches	
	Case 2	Case 4
1	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₅ ,S ₇ ,S ₁₃ ,S ₁₄ ,S ₁₅	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₆ ,S ₇ ,S ₉ ,S ₁₀ ,S ₁₄
2	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₅ ,S ₇ ,S ₁₃ ,S ₁₄ ,S ₁₅	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₆ ,S ₇ ,S ₉ ,S ₁₀ ,S ₁₄
3	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₇ ,S ₁₀ ,S ₁₃ ,S ₁₄ ,S ₁₅	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₆ ,S ₇ ,S ₉ ,S ₁₀ ,S ₁₄
4	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₇ ,S ₁₀ ,S ₁₃ ,S ₁₄ ,S ₁₅	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₆ ,S ₇ ,S ₉ ,S ₁₀ ,S ₁₄
5	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₇ ,S ₁₀ ,S ₁₃ ,S ₁₄ ,S ₁₅	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₆ ,S ₇ ,S ₈ ,S ₁₀ ,S ₁₄
6	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₅ ,S ₇ ,S ₁₀ ,S ₁₄ ,S ₁₅	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₅ ,S ₇ ,S ₈ ,S ₁₃ ,S ₁₄
7	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₅ ,S ₇ ,S ₁₁ ,S ₁₄ ,S ₁₅	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₅ ,S ₇ ,S ₈ ,S ₁₃ ,S ₁₄
8	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₅ ,S ₇ ,S ₁₁ ,S ₁₄ ,S ₁₅	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₅ ,S ₇ ,S ₉ ,S ₁₀ ,S ₁₄
9	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₅ ,S ₇ ,S ₁₁ ,S ₁₄ ,S ₁₅	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₅ ,S ₇ ,S ₉ ,S ₁₀ ,S ₁₄
10	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₅ ,S ₇ ,S ₁₁ ,S ₁₄ ,S ₁₅	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₅ ,S ₇ ,S ₉ ,S ₁₀ ,S ₁₄
11	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₅ ,S ₇ ,S ₁₁ ,S ₁₄ ,S ₁₅	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₇ ,S ₉ ,S ₁₀ ,S ₁₁ ,S ₁₄
12	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₅ ,S ₇ ,S ₁₁ ,S ₁₄ ,S ₁₅	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₇ ,S ₉ ,S ₁₀ ,S ₁₁ ,S ₁₄
13	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₅ ,S ₇ ,S ₁₁ ,S ₁₄ ,S ₁₅	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₇ ,S ₉ ,S ₁₀ ,S ₁₁ ,S ₁₄
14	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₅ ,S ₇ ,S ₁₁ ,S ₁₄ ,S ₁₅	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₅ ,S ₇ ,S ₉ ,S ₁₁ ,S ₁₄
15	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₅ ,S ₇ ,S ₁₁ ,S ₁₄ ,S ₁₅	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₅ ,S ₇ ,S ₉ ,S ₁₁ ,S ₁₄
16	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₅ ,S ₇ ,S ₁₁ ,S ₁₄ ,S ₁₅	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₅ ,S ₇ ,S ₉ ,S ₁₁ ,S ₁₄
17	S ₁ ,S ₂ ,S ₄ ,S ₅ ,S ₇ ,S ₈ ,S ₁₁ ,S ₁₂ ,S ₁₄	S ₁ ,S ₂ ,S ₄ ,S ₅ ,S ₇ ,S ₉ ,S ₁₁ ,S ₁₂ ,S ₁₄
18	S ₁ ,S ₂ ,S ₄ ,S ₇ ,S ₉ ,S ₁₀ ,S ₁₁ ,S ₁₂ ,S ₁₄	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₇ ,S ₁₀ ,S ₁₂ ,S ₁₄ ,S ₁₅
19	S ₁ ,S ₂ ,S ₄ ,S ₅ ,S ₇ ,S ₁₀ ,S ₁₂ ,S ₁₄ ,S ₁₅	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₇ ,S ₈ ,S ₁₀ ,S ₁₂ ,S ₁₄
20	S ₁ ,S ₂ ,S ₄ ,S ₅ ,S ₇ ,S ₁₀ ,S ₁₂ ,S ₁₄ ,S ₁₅	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₇ ,S ₈ ,S ₁₀ ,S ₁₂ ,S ₁₄
21	S ₁ ,S ₂ ,S ₄ ,S ₅ ,S ₇ ,S ₁₀ ,S ₁₂ ,S ₁₄ ,S ₁₅	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₇ ,S ₈ ,S ₁₀ ,S ₁₃ ,S ₁₄
22	S ₁ ,S ₂ ,S ₄ ,S ₅ ,S ₆ ,S ₇ ,S ₁₀ ,S ₁₄ ,S ₁₅	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₇ ,S ₈ ,S ₁₀ ,S ₁₃ ,S ₁₄
23	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₈ ,S ₉ ,S ₁₀ ,S ₁₃ ,S ₁₄	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₅ ,S ₇ ,S ₈ ,S ₁₀ ,S ₁₄
24	S ₁ ,S ₂ ,S ₃ ,S ₄ ,S ₈ ,S ₉ ,S ₁₀ ,S ₁₃ ,S ₁₄	S ₁ ,S ₂ ,S ₃ ,S ₅ ,S ₇ ,S ₈ ,S ₁₀ ,S ₁₃ ,S ₁₄




(a) Case 2




(b) Case 4

Fig. 6. The hourly switching in cases 2 and 4.




(a) Network topology at 10 a.m.


1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65



(b) Network topology at 17 p.m.



(c) Network topology at 18 p.m.




(d) Network topology at 21 p.m.

Fig. 7. Different topologies obtained for the network in case 4.


Figs. 8a-8d illustrates the system voltage in per unit (p.u.) for different case studies through box plots. The allowable range of voltage variation is considered to be + or -10% (between 0.9 p.u. to 1.1 p.u.). As these figures depict, the voltage has remained within the permitted range in all cases. The results, obtained in Cases 2 and 4 show that the DFR and increased local power generation have all led to the lower voltage drop over the initial hours, compared to Cases 1 and 3. Besides, the outliers in Cases 1 and 3 indicate that the voltage fluctuation is much more in comparison with the other two case studies. The hourly aggregated power, generated by DERs in the four case studies, is demonstrated in Figs. 9a and 9b. As can be observed, the amount of power, produced by DERs in Cases 2 and 4 is higher than Cases 1 and 3. The analysis of Fig. 9a illustrates that the

1
2
3
4 power generated by DERs during the operation period (24 hours) in Cases 1 and 2 are 289.326
5
6 MW and 295.773 MW, respectively, which shows a 2.23% increase in generation due to the use
7
8 of DFR. Besides, a closer look at Fig. 9b indicates that the power generated by DERs in Cases 3
9
10 and 4 are 287.622 MW and 294.461 MW, respectively. Therefore, in these cases, the high effect
11
12 of DFR on increasing the generation of DERs is proved. It should be noted that the implementation
13
14 of DFR allows the exchange of power between microgrids in many hours in Cases 2 and 4. While
15
16 in Cases 1 and 3, it is not possible for microgrids to transact power over some hours due to the
17
18 topological limitations of the system. Thus, microgrids transact power only with the upstream
19
20 network.
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65




(a) Case 1

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65




(b) Case 2




(c) Case 3

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65




(d) Case 4

Fig. 8. The voltage magnitude at each hour.



(a) Cases 1 and 2



(b) Cases 3 and 4
 Fig. 9. Total power generated by DERs in different cases.

Figs. 10a-10d depict the optimal scheduling of a smart home, located in microgrid 3 for the four case studies. As can be seen, in Cases 1 and 2, some devices are not activated in the customers' preferred range (presented in Table 5), while in case 3, only two appliances (electric kettle and toaster) are not activated in the customers' preferred range. This is due to the consumers' comfort index being considered as one of the objective functions. As can be seen from Fig. 10d, the comfort index of the smart homes located in microgrid 3 is 100% in Case 4 and the scheduling is quite in accordance with the consumer's preferences. The schedules obtained for smart homes located on other microgrids are presented in appendix (Figs. 12-20).

Figs. 11a-11j depict the operating points of smart homes' EES systems. As can be seen, the operating points of all systems are almost the same. According to the figures, these systems are charged during off-peak hours and discharged during peak hours. In general, this performance reduces the purchase of power during peak hours and consequently reduces the cost of electricity bills.







Fig. 10. The obtained scheduling for a smart home in microgrid 3.







(e) EES system at node 50




(f) EES system at node 86




(g) EES system at node 74



(h) EES system at node 96



(i) EES system at node 102



(j) EES system at node 114

Fig. 11. The operating point of EES systems located in smart homes.

6- Conclusion

This paper presents a two-stage stochastic MILP framework for energy management of active distribution systems consisting of interconnected microgrids. The network studied in this paper was a modified 118-bus radial distribution system consisting of 10 microgrids in which traditional loads and smart homes were considered. In the proposed model, DSO performed the main grid scheduling with observance of optimal scheduling of microgrids and with the possibility of DFR

1
2
3
4 implementation. Finally, the model was solved in the form of 4 case studies and the results are
5
6 summarized as follows:

- 7
8
9 • Microgrid scheduling problem was solved with both single-objective and two-objective
10
11 methods and the results mirrored that the use of two-objective method despite a 5.65%
12
13 increase in operating costs led to a significant increase in consumer's comfort index.
14
15
- 16 • The main grid scheduling problem was solved by considering both fixed and dynamic
17
18 topologies and the results illustrated that automatic switching reduced the total operating
19
20 cost by 9.71% and increased the consumer's comfort index by about 0.2%. In addition, the
21
22 results mirrored that automatic switching reduces the final scheduling deviation of
23
24 microgrids from their optimal program.
25
26
- 27 • Examination of the operating point of EES systems demonstrated that these systems were
28
29 charged during off-peak hours when the price of electricity was cheap and discharged
30
31 during peak hours when the price of electricity was high, thus reducing operating costs.
32
33
34

35
36 Overall, the results proved that the two-level model proposed in this paper is an optimal framework
37
38 for managing distribution systems consisting of interconnected microgrids.
39
40
41
42
43
44

45 **Acknowledgement**

46
47 M.S. Javadi and J.P.S. Catalão acknowledge the support by FEDER funds through COMPETE
48
49 2020 and by Portuguese funds through FCT, under 02/SAICT/2017 (POCI-01-0145-FEDER-
50
51 029803).
52
53

54 **Appendix**

55
56
57
58 The schedules obtained for the smart homes in different microgrids are provided in Figs. 12-20.
59
60
61
62
63
64
65

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65




Fig. 12. The obtained scheduling for a smart home in microgrid 1.




Fig. 13. The obtained scheduling for a smart home in microgrid 2.






Fig. 14. The obtained scheduling for a smart home in microgrid 4.




(c) Case 3

(d) Case 4


Fig. 15. The obtained scheduling for a smart home in microgrid 5.




(a) Case 1



(b) Case 2




(c) Case 3




(d) Case 4

Fig. 16. The obtained scheduling for a smart home in microgrid 6.




(a) Case 1




(b) Case 2

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65




(c) Case 3




(d) Case 4


Fig. 17. The obtained scheduling for a smart home in microgrid 7.




(a) Case 1



(b) Case 2





(c) Case 3



(d) Case 4

Fig. 18. The obtained scheduling for a smart home in microgrid 8.



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65




Fig. 19. The obtained scheduling for a smart home in microgrid 9.




Fig. 20. The obtained scheduling for a smart home in microgrid 10.

References

[1] Wang Y, Rousis AO, Strbac G. On microgrids and resilience: A comprehensive review on modeling and operational strategies. *Renew Sustain Energy Rev* 2020;134:110313. <https://doi.org/https://doi.org/10.1016/j.rser.2020.110313>.

[2] Chen B, Wang J, Lu X, Chen C, Zhao S. Networked Microgrids for Grid Resilience, Robustness, and Efficiency: A Review. *IEEE Trans Smart Grid* 2021;12:18–32.

- 1
2
3
4 <https://doi.org/10.1109/TSG.2020.3010570>.
- 5 [3] Bandejas F, Pinheiro E, Gomes M, Coelho P, Fernandes J. Review of the cooperation and
6 operation of microgrid clusters. *Renew Sustain Energy Rev* 2020;133:110311.
7 <https://doi.org/https://doi.org/10.1016/j.rser.2020.110311>.
- 8 [4] Phommixay S, Doumbia ML, Lupien St-Pierre D. Review on the cost optimization of
9 microgrids via particle swarm optimization. *Int J Energy Environ Eng* 2020;11:73–89.
10 <https://doi.org/10.1007/s40095-019-00332-1>.
- 11 [5] Kumar KP, Saravanan B. Recent techniques to model uncertainties in power generation
12 from renewable energy sources and loads in microgrids – A review. *Renew Sustain*
13 *Energy Rev* 2017;71:348–58. <https://doi.org/https://doi.org/10.1016/j.rser.2016.12.063>.
- 14 [6] Komala K, Kumar KP, Cherukuri SHC. Storage and non-Storage Methods of Power
15 balancing to counter Uncertainty in Hybrid Microgrids - A review. *J Energy Storage*
16 *2021;36:102348*. <https://doi.org/https://doi.org/10.1016/j.est.2021.102348>.
- 17 [7] Harsh P, Das D. Energy management in microgrid using incentive-based demand response
18 and reconfigured network considering uncertainties in renewable energy sources. *Sustain*
19 *Energy Technol Assessments* 2021;46:101225.
20 <https://doi.org/10.1016/j.seta.2021.101225>.
- 21 [8] Adefarati T, Bansal RC. Reliability, economic and environmental analysis of a microgrid
22 system in the presence of renewable energy resources. *Appl Energy* 2019;236:1089–114.
23 <https://doi.org/https://doi.org/10.1016/j.apenergy.2018.12.050>.
- 24 [9] Vincent R, Ait-Ahmed M, Houari A, Benkhoris MF. Residential microgrid energy
25 management considering flexibility services opportunities and forecast uncertainties. *Int J*
26 *Electr Power Energy Syst* 2020;120:105981. <https://doi.org/10.1016/j.ijepes.2020.105981>.
- 27 [10] Leonori S, Martino A, Frattale Mascioli FM, Rizzi A. Microgrid Energy Management
28 Systems Design by Computational Intelligence Techniques. *Appl Energy*
29 *2020;277:115524*. <https://doi.org/https://doi.org/10.1016/j.apenergy.2020.115524>.
- 30 [11] Leonori S, Paschero M, Frattale Mascioli FM, Rizzi A. Optimization strategies for
31 Microgrid energy management systems by Genetic Algorithms. *Appl Soft Comput*
32 *2020;86:105903*. <https://doi.org/https://doi.org/10.1016/j.asoc.2019.105903>.
- 33 [12] Marino CA, Marufuzzaman M. A microgrid energy management system based on chance-
34 constrained stochastic optimization and big data analytics. *Comput Ind Eng*
35 *2020;143:106392*. <https://doi.org/10.1016/j.cie.2020.106392>.
- 36 [13] Ding T, Lin Y, Bie Z, Chen C. A resilient microgrid formation strategy for load
37 restoration considering master-slave distributed generators and topology reconfiguration.
38 *Appl Energy* 2017;199:205–16.
39 <https://doi.org/https://doi.org/10.1016/j.apenergy.2017.05.012>.
- 40 [14] Li Z, Wang S, Zhou Y, Liu W, Zheng X. Optimal distribution systems operation in the
41 presence of wind power by coordinating network reconfiguration and demand response.
42 *Int J Electr Power Energy Syst* 2020;119:105911.
43 <https://doi.org/10.1016/j.ijepes.2020.105911>.
- 44 [15] Wang J, Wang W, Yuan Z, Wang H, Wu J. A Chaos Disturbed Beetle Antennae Search
45 Algorithm for a Multiobjective Distribution Network Reconfiguration Considering the
46 Variation of Load and DG. *IEEE Access* 2020;8:97392–407.
47 <https://doi.org/10.1109/access.2020.2997378>.
- 48 [16] İnci M, Aygen MS. A modified energy management scheme to support phase balancing in
49 grid interfaced photovoltaic/fuel cell system. *Ain Shams Eng J* 2021.
- 50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65

- 1
2
3
4 <https://doi.org/https://doi.org/10.1016/j.asej.2020.12.018>.
- 5 [17] Zareen N, Mustafa MW, Sultana U, Nadia R, Khattak MA. Optimal real time cost-benefit
6 based demand response with intermittent resources. *Energy* 2015;90:1695–706.
7 <https://doi.org/https://doi.org/10.1016/j.energy.2015.06.126>.
- 8 [18] Hafeez G, Wadud Z, Khan IU, Khan I, Shafiq Z, Usman M, et al. Efficient Energy
9 Management of IoT-Enabled Smart Homes Under Price-Based Demand Response
10 Program in Smart Grid. *Sensors (Basel)* 2020;20:3155. <https://doi.org/10.3390/s20113155>.
- 11 [19] ur Rehman U, Yaqoob K, Adil Khan M. Optimal power management framework for smart
12 homes using electric vehicles and energy storage. *Int J Electr Power Energy Syst*
13 2022;134:107358. <https://doi.org/10.1016/j.ijepes.2021.107358>.
- 14 [20] Dey B, García Márquez FP, Basak SK. Smart Energy Management of Residential
15 Microgrid System by a Novel Hybrid MGWOSCACSA Algorithm. *Energies*
16 2020;13:3500. <https://doi.org/10.3390/en13133500>.
- 17 [21] Rocha HRO, Honorato IH, Fiorotti R, Celeste WC, Silvestre LJ, Silva JAL. An Artificial
18 Intelligence based scheduling algorithm for demand-side energy management in Smart
19 Homes. *Appl Energy* 2021;282:116145. <https://doi.org/10.1016/j.apenergy.2020.116145>.
- 20 [22] Wang J, Liu J, Li C, Zhou Y, Wu J. Optimal scheduling of gas and electricity
21 consumption in a smart home with a hybrid gas boiler and electric heating system. *Energy*
22 2020;204:117951. <https://doi.org/https://doi.org/10.1016/j.energy.2020.117951>.
- 23 [23] Behzadi A, Arabkoohsar A. Feasibility study of a smart building energy system
24 comprising solar PV/T panels and a heat storage unit. *Energy* 2020;210:118528.
25 <https://doi.org/https://doi.org/10.1016/j.energy.2020.118528>.
- 26 [24] Nikmehr N. Distributed robust operational optimization of networked microgrids
27 embedded interconnected energy hubs. *Energy* 2020;199:117440.
28 <https://doi.org/https://doi.org/10.1016/j.energy.2020.117440>.
- 29 [25] Tan B, Chen H. Multi-objective energy management of multiple microgrids under random
30 electric vehicle charging. *Energy* 2020;208:118360.
31 <https://doi.org/https://doi.org/10.1016/j.energy.2020.118360>.
- 32 [26] Safaie AA, Alizadeh Bidgoli M, Javadi S. A multi-objective optimization framework for
33 integrated electricity and natural gas networks considering smart homes in downward
34 under uncertainties. *Energy* 2022;239:122214.
35 <https://doi.org/https://doi.org/10.1016/j.energy.2021.122214>.
- 36 [27] Alizadeh Bidgoli M, Ahmadian A. Multi-stage optimal scheduling of multi-microgrids
37 using deep-learning artificial neural network and cooperative game approach. *Energy*
38 2022;239:122036. <https://doi.org/https://doi.org/10.1016/j.energy.2021.122036>.
- 39 [28] Mukhopadhyay B, Das D. Multi-objective dynamic and static reconfiguration with
40 optimized allocation of PV-DG and battery energy storage system. *Renew Sustain Energy*
41 *Rev* 2020;124:109777. <https://doi.org/10.1016/j.rser.2020.109777>.
- 42 [29] Guo S, Lin J, Zhao Y, Wang L, Wang G, Liu G. A Reliability-Based Network
43 Reconfiguration Model in Distribution System with DGs and ESSs Using Mixed-Integer
44 Programming. *Energies* 2020;13. <https://doi.org/10.3390/en13051219>.
- 45 [30] Kahouli O, Alsaif H, Bouteraa Y, Ben Ali N, Chaabene M. Power System
46 Reconfiguration in Distribution Network for Improving Reliability Using Genetic
47 Algorithm and Particle Swarm Optimization. *Appl Sci* 2021;11.
48 <https://doi.org/10.3390/app11073092>.
- 49 [31] Xu X, Hu W, Liu W, Du Y, Huang R, Huang Q, et al. Risk management strategy for a
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65

- 1
2
3
4 renewable power supply system in commercial buildings considering thermal comfort and
5 stochastic electric vehicle behaviors. *Energy Convers Manag* 2021;230:113831.
6 <https://doi.org/10.1016/j.enconman.2021.113831>.
- 7
8 [32] Akter MN, Mahmud MA, Haque ME, Oo AMT. An optimal distributed energy
9 management scheme for solving transactive energy sharing problems in residential
10 microgrids. *Appl Energy* 2020;270:115133.
11 <https://doi.org/10.1016/j.apenergy.2020.115133>.
- 12
13 [33] Nunna HSVSK, Sesetti A, Rathore AK, Doolla S. Multiagent-Based Energy Trading
14 Platform for Energy Storage Systems in Distribution Systems With Interconnected
15 Microgrids. *IEEE Trans Ind Appl* 2020;56:3207–17.
16 <https://doi.org/10.1109/tia.2020.2979782>.
- 17
18 [34] Haseeb M, Kazmi SAA, Malik MM, Ali S, Bukhari SBA, Shin DR. Multi Objective
19 Based Framework for Energy Management of Smart Micro-Grid. *IEEE Access*
20 2020;8:220302–19. <https://doi.org/10.1109/access.2020.3041473>.
- 21
22 [35] Violante W, Canizares CA, Trovato MA, Forte G. An Energy Management System for
23 Isolated Microgrids With Thermal Energy Resources. *IEEE Trans Smart Grid*
24 2020;11:2880–91. <https://doi.org/10.1109/tsg.2020.2973321>.
- 25
26 [36] Alhasnawi BN, Jasim BH, Rahman Z-ASA, Siano P. A Novel Robust Smart Energy
27 Management and Demand Reduction for Smart Homes Based on Internet of Energy.
28 *Sensors (Basel)* 2021;21:4756. <https://doi.org/10.3390/s21144756>.
- 29
30 [37] Jiménez M, Bilbao A. Pareto-optimal solutions in fuzzy multi-objective linear
31 programming. *Fuzzy Sets Syst* 2009;160:2714–21.
32 <https://doi.org/10.1016/j.fss.2008.12.005>.
- 33
34 [38] Yuan H, Li F, Wei Y, Zhu J. Novel linearized power flow and linearized OPF models for
35 active distribution networks with application in distribution LMP. *IEEE Trans Smart Grid*
36 2018;9:438–48. <https://doi.org/10.1109/TSG.2016.2594814>.
- 37
38 [39] Haghghat H, Zeng B. Distribution System Reconfiguration under Uncertain Load and
39 Renewable Generation. *IEEE Trans Power Syst* 2016;31:2666–75.
40 <https://doi.org/10.1109/TPWRS.2015.2481508>.
- 41
42 [40] Mansouri SA, Ahmarinejad A, Nematbakhsh E, Javadi MS, Jordehi AR, Catalão JPS.
43 Energy Management in Microgrids including Smart Homes: A Multi-objective Approach.
44 *Sustain Cities Soc* 2021;102852. <https://doi.org/10.1016/j.scs.2021.102852>.
- 45
46 [41] Eladl AA, El-Afifi MI, Saeed MA, El-Saadawi MM. Optimal operation of energy hubs
47 integrated with renewable energy sources and storage devices considering CO2 emissions.
48 *Int J Electr Power Energy Syst* 2020;117:105719.
49 <https://doi.org/10.1016/j.ijepes.2019.105719>.
- 50
51 [42] Amir Mansouri S, Javadi MS, Ahmarinejad A, Nematbakhsh E, Zare A, Catalão JPS. A
52 coordinated energy management framework for industrial, residential and commercial
53 energy hubs considering demand response programs. *Sustain Energy Technol*
54 *Assessments* 2021;47:101376. <https://doi.org/10.1016/j.seta.2021.101376>.
- 55
56 [43] Bui VH, Hussain A, Kim HM. A multiagent-based hierarchical energy management
57 strategy for multi-microgrids considering adjustable power and demand response. *IEEE*
58 *Trans Smart Grid* 2018;9:1323–33. <https://doi.org/10.1109/TSG.2016.2585671>.
- 59
60 [44] Wan J, Zheng F, Luan H, Tian Y, Li L, Ma Z, et al. Assessment of wind energy resources
61 in the urat area using optimized weibull distribution. *Sustain Energy Technol Assessments*
62 2021;47:101351. <https://doi.org/10.1016/j.seta.2021.101351>.
- 63
64
65

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65

[45] Newlun CJ, McCalley JD, Amitava R, Ardakani AJ, Venkatraman A, Acevedo ALF-. Adaptive Expansion Planning Framework for MISO Transmission Planning Process. 2021 IEEE Kansas Power Energy Conf., 2021, p. 1–6. <https://doi.org/10.1109/KPEC51835.2021.9446221>.

[46] Alabedin AMZ, El-Saadany EF, Salama MMA. Generation scheduling in Microgrids under uncertainties in power generation. 2012 IEEE Electr. Power Energy Conf., 2012, p. 133–8. <https://doi.org/10.1109/EPEC.2012.6474937>.

[47] Zhang D, Fu Z, Zhang L. An improved TS algorithm for loss-minimum reconfiguration in large-scale distribution systems. *Electr Power Syst Res* 2007;77:685–94. <https://doi.org/10.1016/j.epsr.2006.06.005>.